

EXDIRECT

EU & IECEx Attestation of Conformity

Issued in accordance with ISO/IEC 17050-1:2004.

We,

ExDirect
233 South Street
Hopkinton, MA 01748 USA

as the manufacturer, attest under our sole responsibility that the product(s),

EX200, EX500, EX550, and EX700 Series Enclosures

to which this attestation relates, conform to the relevant provisions of the IECEx, ATEX Directive 2014/34/EU, and RoHS Directive 2011/65/EU.

Product Markings:



II 2 G D
Ex db IIC Gb
Ex tb IIIC Db
IP66/IP68
Tamb = -55°C to +85°C
Notified Body: 2813

Conformity has been demonstrated with reference to the following documentation:

ATEX EU Type Examination Certificate: Sira 19ATEX1252U

ATEX Notified Body for EU Type Examination Certificate: CSA Group Netherlands B.V. (Notified Body number 2813)
Utrechtseweg 310
6812 AR, Arnhem, Netherlands

ATEX Quality Assurance Notification No.: SIRA 10 ATEX M462

ATEX Notified Body for Quality Assurance: CSA Group Netherlands B.V. (Notified Body number 2813)
Utrechtseweg 310
6812 AR, Arnhem, Netherlands

IECEx Type Examination Certificate: IECEx SIR 19.0075U

IECEx Notified Body for IECEx Type Examination Certificate: CSA Group Netherlands B.V.
Utrechtseweg 310
6812 AR, Arnhem, Netherlands

IECEx Quality Assessment Report No.: GB/SIR/QAR10.0005/13

IECEx Notified Body for Quality Assessment: CSA Group Netherlands B.V.
Utrechtseweg 310
6812 AR, Arnhem, Netherlands

Compliance with the Essential Health & Safety Requirements has been assessed by reference to the following standards:

EN 60079-0:2018	IEC 60079-0:2017
EN 60079-1:2014	IEC 60079-1:2014
EN 60079-31:2014	IEC 60079-31:2013

The standard IEC 60079-31:2013 is no longer harmonized. The requirements of this standard have been checked against the harmonized standard IEC 60079-31:2022 and there were no major technical changes affecting the latest technical knowledge for the products listed above.

Signed for and on behalf of ExDirect:

Name: Jeffrey Peters
Company: ExDirect
Title: President
Date: March 30, 2023

Document No: EU & IECEx DoC EX Series {033023}